

TEST REPORT: 7191168589-CHM17-01-CSY

Date: 23 AUG 2017

Tel: +65 68851312 Fax: +65 67784301

Client's Ref:

Email: zhou.xiao@tuv-sud-psb.sg

Note: This report is issued subject to the Testing and Certification Regulations of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.



PSB Singapore

Choose certainty.
Add value.

SUBJECT

Evaluation of Sealant samples

CLIENT

PFE Technologies Pte Ltd
No 9 Gul Street 4
Singapore 629238

Attn : Mr Hans Goh

DESCRIPTION OF SAMPLE

One sealant sample labelled as follows were received on 28 Jul 2017.

Product name	Quantity
PERESEAL 702	1 x 300 ml

DATE OF TEST

10 Aug 2017 – 18 Aug 2017



Laboratory:
TÜV SÜD PSB Pte. Ltd.
No.1 Science Park Drive
Singapore 118221

Phone : +65-6885 1333
Fax : +65-6776 8670
E-mail: enquiries@tuv-sud-psb.sg
www.tuv-sud-psb.sg
Co. Reg : 199002667R

Regional Head Office:
TÜV SÜD Asia Pacific Pte. Ltd.
1 Science Park Drive, #02-01
Singapore 118221
TÜV®

METHOD OF TEST

The sample was tested in the "as-received" condition.

<u>Test</u>	<u>Method</u>
1) Volatile organic compound content	As per LEED IEQc4.1: Low-Emitting Materials - Adhesives and Sealants, and according to South Coast Air Quality Management District (SCAQMD) Rule #1168 Adhesive and Sealant Applications recommend test method: US EPA Method 24 "Determination of volatile matter content, water content, density, volume solids, and weight solids of surface coatings" as reference

RESULTS

Table 1 : The Volatile Organic Compound (VOC) Content Results

Sample	Result ^a
PERESEAL 702	53.1 g/L

a) The result was calculated based on the specific gravity = 1.5 g/cm³ provided by client

SUMMARY OF TEST RESULTS

The summary of test results for "PERESEAL 702".

Test	Result	LEED IEQc4.1: Low-Emitting Materials - Adhesives and Sealants Requirement		Inferred Remark
		Sealants VOC Limit [g/L less water]		
VOC Content	53.1 g/L	Architectural	< 250 g/L	Pass
		Roadway	< 250 g/L	

* Adhesives, Sealants and Sealant Primers must comply with South Coast Air Quality Management District (SCAQMD) Rule #1168. Volatile organic compound (VOC) limits listed in the table below correspond to an effective date of July 1, 2005 and rule amendment date of January 7, 2005.



MS CHOO SEOW YAH
TECHNICAL EXECUTIVE



DR XIAO ZHOU
PRODUCT MANAGER
MICROCONTAMINATION DIAGNOSIS
CHEMICAL & MATERIALS

TEST REPORT: 7191168589-CHM17-01-CSY
23 AUG 2017



PSB Singapore

Please note that this Report is issued under the following terms :

1. This report applies to the sample of the specific product/equipment given at the time of its testing/calibration. The results are not used to indicate or imply that they are applicable to other similar items. In addition, such results must not be used to indicate or imply that TÜV SÜD PSB approves, recommends or endorses the manufacturer, supplier or user of such product/equipment, or that TÜV SÜD PSB in any way "guarantees" the later performance of the product/equipment. Unless otherwise stated in this report, no tests were conducted to determine long term effects of using the specific product/equipment.
2. The sample/s mentioned in this report is/are submitted/supplied/manufactured by the Client. TÜV SÜD PSB therefore assumes no responsibility for the accuracy of information on the brand name, model number, origin of manufacture, consignment or any information supplied.
3. Nothing in this report shall be interpreted to mean that TÜV SÜD PSB has verified or ascertained any endorsement or marks from any other testing authority or bodies that may be found on that sample.
4. This report shall not be reproduced wholly or in parts and no reference shall be made by the Client to TÜV SÜD PSB or to the report or results furnished by TÜV SÜD PSB in any advertisements or sales promotion.
5. Unless otherwise stated, the tests were carried out in TÜV SÜD PSB Pte Ltd, No.1 Science Park Drive Singapore 118221.

July 2011

